

	Oxic chamber	s.w.d.	3 m	C-1446					
				CM tank model					
		mgd		U.S. GPM					
wastewater flow	7570 m3/day	2,000		1388.9					
BOD in (mg/L)	200		3336.0 lbBOD/day	5004.0 lbO2/day					
TKN in (mg/L)	0		0.0 lbTKN/day	0.0 lbO2/day					
			AOR	5004.0 lbO2/day	208.5 lbO2/hr				
cell I									
length	42 m			HP/mg	HP for mixing	if CFM for mixing			
width	30 m	tank volume	residence (days)	80	79.9	1627 CFM			
s.w.d.	3 m	3780.0 m3	0.50	90	89.9				
	9.84 (feet)	0.999 mg		100	99.9				
			lbBOD/day 1000 cu.ft.	25.0	MLSS	3000			
			lbBOD/day acre	10714.9	f/m	0.134			
							hi speed	low speed	
							119.1	91.6	
total tankage volume	0.999 mg								
total residence time	0.50 days								
AOR	AOR/SOR	SOR	HP at 2.5 lb/h per HP	de-rate 5	de-rate 10	de-rate 15	HP/mg	HP for mixing	HP per 1,000 cu.ft.
208.5	0.7	297.9	119.1	125.4	132.4	140.2	80	79.9	0.89
208.5	0.6	347.5	139.0	146.3	154.4	163.5	90	89.9	1.04
208.5	0.5	417.0	166.8	175.6	185.3	196.2	100	99.9	1.25

quick-and-dirty diffused aeration estimates
 CFM for diffused aeration/oxygen transfer 3619 CFM AOR/SOR = .37 1.7% per feet 4705 CFM 7994 m3/h
 HP estimate for oxygen 125.4 HP with 1.3 safety factor 5.34 psig 369 mbar
 5.84 psig(PeakOverdesign) 403 mbar

- notes:
 2. I'm adding some token TKN, used at full value for HP calculation, although some nitrogen would be used up for normal biological/BOD processes
 3. approach would be extended/activated sludge alternative using f/m= c. 0.1 and 300 gpd/sq.ft. for a secondary clarifier
 4. Possible preliminary quote:

about 98.0 HP if low speed units
 about 588 1-m tubes at 8 CFM per tube with 1.3 safety factor or suitable disc make/model
 163.0 HP blowers

other related calcs:

				area (m2)					
secondary clarifier diameter at 300 gpd/sq.ft.			28.1 m	619.4	12733 ft lb torque				
waste sludge flow Qw for various sludge age values, 30 mg/L SSout, underflow SS at				0.5 %	Hammer.412				
		WAS (see footnote # 1)			RAS (see footnote #2)	tentative at	8 hr/day	thickener	
age days	Qw mgd	Qw gpd	Qw gpm	lb/day dry	Qw/flow in	Qr mgd	Qr/Q	BFP gpm at 4%	regime
5	0.1078	107841	74.9	4491.6	5.4 %	2.7004	135.0 %	28.1	diam. (m)
10	0.0479	47921	33.3	1995.9	2.4 %	2.8502	142.5 %	12.5	10.3
14.5	0.0293	29325	20.4	1221.4	1.5 %	2.8967	144.8 %	7.6	6.9
15	0.0279	27947	19.4	1164.0	1.4 %	2.9001	145.0 %	7.3	5.4
25	0.0120	11968	8.3	498.5	0.6 %	2.9401	147.0 %	3.1	5.2
									3.4
									14302 ft lb torque
									6355 ft lb torque
									3889 ft lb torque
									3706 ft lb torque
									1587 ft lb torque

dry weight sludge as predicted by Hammer.440 Figure 11-40 as a function of f/m known to be "reasonable" for municipal but may differ considerably if industrial ww
 lb/day dry 2406.8 2 * K * mgd * 8.33 * BOD5 mg/L
 tentative BFP gpm for possible inlet SS settings ballpark/alternate figures at above specified net BFP hours per day
 20.1 3% 9631 gpd
 17.2 3.5% 8255 gpd
 15.0 4% 7223 gpd
 sludge yield (lb/day dry / lbBOD/day) = 0.72
 dewatering block subject to review/actual operating regime

foot note # 1 Assuming treated wastewater exits clarifier with say 30 mg/L SS and using entered/calculated tank MLSS,V solving for Qw in sludge age equation (11-12- Hammer.412) for various age settings results in WAS estimates as shown

foot note # 2 Tentative Qr's result from performing somewhat crude mass balance around secondary clarifier (solving for RAS):
 (Q+Qr) * MLSS = Q * 30 mg/L + (Qw+Qr) * underflow SS in mg/L
 Return sludge rates to be fine tuned as will probably operate in an A2/O fashion - more later
 (It all depends how lucky we are with underflow SSs: 0.5 - 2%)

Although not shown, it is assumed some thickener/DAF is used to concentrate settler underflow up to 4%
 (Hammer.443: "As a general rule, the solids content must be at least 4 percent for feasible dewatering")

quotables/summary (tentative)

surface aerators
 retrievable tubes & blowers local sourcing of PE/PVC pipe/panel/other

- www.Aireadores.Net
- www.VirtualGuild.Net
- www.balestie.com
- www.LodosActivados.com