

Oxic chamber
s.w.d. 4.5 m

CM tank model

wastewater flow 37850 m3/day
BOD in (mg/L) 204
TKN in (mg/L) 34

10,000 mgd
17013.6 lbBOD/day
2835.6 lbTKN/day

AOR 38564.2 lbO2/day
1606.8 lbO2/hr

25520.4 lbO2/day
13043.8 lbO2/day

cell I

length 68 m
width 68 m
s.w.d. 4.5 m
14.76 (feet)

tank volume 20808.0 m3
5.497 mg

residence (days) 0.55

HP/mg 50
60
70

HP for mixing 274.9
329.8
384.8

if CFM for mixing 5971 CFM

lbBOD/day 1000 cu.ft. 23.2
lbBOD/day acre 14890.6

MLSS 3500
f/m 0.106

hi speed 918.2
low speed 706.3

total tankage volume 5.497 mg
total residence time 0.55 days

AOR	AOR/SOR	SOR	HP at 2.5 lb/h per HP	de-rate 5	de-rate 10	de-rate 15	HP/mg	HP for mixing
1606.8	0.7	2295.5	918.2	966.5	1020.2	1080.2	50	274.9
1606.8	0.6	2678.1	1071.2	1127.6	1190.3	1260.3	60	329.8
1606.8	0.5	3213.7	1285.5	1353.1	1428.3	1512.3	70	384.8

quick-and-dirty diffused aeration estimates
CFM for diffused aeration/oxygen transfer 17920 CFM
HP estimate for oxygen 849.9 HP

AOR/SOR = .37
1.7% per feet

23296 CFM
with 1.3 safety factor
7.48 psig
7.98 psig(PeakOverdesign)

516 mbar
550 mbar

notes:

3. approach would be extended/activated sludge alternative using f/m= c. 0.1 and 300 gpd/sq.ft. for a secondary clarifier

4. Possible preliminary quote (low speed):

about 755.0 HP if low speed units
about 2912 1-m tubes at 8 CFM per tube with 1.3 safety factor
1104.9 HP blowers

other related calcs:

secondary clarifier diameter at 300 gpd/sq.ft. 62.8 m
63664 ft lb torque

waste sludge flow Qw for various sludge age values, 30 mg/L SSout, underflow SS at 0.7 % Hammer.412

age days	Qw mgd	Qw gpd	Qw gpm	lb/day dry	Qw/flow in	Qr mgd	Qr/Q	BFP gpm at 4%	8 hr/day regime	thickener diam. (m)	thickener
5	0.5069	506892	352.0	29556.9	5.1 %	8.9005	89.0 %	184.8		26.5	94116 ft lb torque
10	0.2320	232017	161.1	13528.9	2.3 %	9.4503	94.5 %	84.6		17.9	43079 ft lb torque
14.5	0.1467	146711	101.9	8554.7	1.5 %	9.6209	96.2 %	53.5		14.2	27240 ft lb torque
15	0.1404	140393	97.5	8186.3	1.4 %	9.6335	96.3 %	51.2		13.9	26067 ft lb torque
25	0.0671	67093	46.6	3912.2	0.7 %	9.7801	97.8 %	24.5		9.6	12457 ft lb torque

dry weight sludge as predicted by Hammer.440 Figure 11-40 as a function of f/m known to be "reasonable" for municipal but may differ considerably if industrial ww

lb/day dry 11740.4
2 * K * mgd * 8.33 * BOD5 mg/L

tentative BFP gpm for possible inlet SS settings ballpark/alternate figures at above specified net BFP hours per day

tentative BFP gpm	%	gpd	sludge yield (lb/day dry / lbBOD/day) =
97.9	3%	46980 gpd	0.69
83.9	3.5%	40269 gpd	
73.4	4%	35235 gpd	

dewatering block subject to review/actual operating regime

foot note # 1 Assuming treated wastewater exits clarifier with say 30 mg/L SS and using entered/calculated tank MLSS,V solving for Qw in sludge age equation (11-12- Hammer.412) for various age settings results in WAS estimates as shown

foot note # 2 Tentative Qr's result from performing somewhat crude mass balance around secondary clarifier (solving for RAS):
(Q+Qr) * MLSS = Q * 30 mg/L + (Qw+Qr) * underflow SS in mg/L
Return sludge rates to be fine tuned as will probably operate in an A2/O fashion - more later
(It all depends how lucky we are with underflow SSs: 0.5 - 2%)

Although not shown, it is assumed some thickener/DAF is used to concentrate settler underflow up to 4%
(Hammer.443: "As a general rule, the solids content must be at least 4 percent for feasible dewatering")

quotables/summary

low speed aerators, e.g. DBS
retrievable tubes & blowers local sourcing of PE/PVC pipe/panel/other

tentative BFP upon review, entry level if at least to break new ground

www.balestie.com